

**Hutchinson Irrigation District #16**  
**Annual Drinking Water Quality Report**  
Mandatory Health-Related Standards Are Established by the Washington State Department of Health

Parameter	Unit of Measure	MCL	Highest Detected Level		Likely Source of Contamination
			MCLG	Source	
<b>Microbiology</b>			2	5	
29 Tests were taken during this reporting period					
<b>Total Coliform Bactria</b>				1 Detection	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this is a warning of potential problems.
<b>Fecal Coliform and E. Coli</b>				No Detections	
<b>Inorganic Chemicals (IOC)</b>					
<b>Nitrate</b>	mg/l	10	10	0.598	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Tests Taken</b>				8/6/2024	
<b>Lead</b>		AL=0.015 mg/l		Sample taken 07/17/24	No detection above action level, Next Sample July- 2027
<b>Copper</b>		AL=1.3 mg/l		Sample taken 07/17/24	No detection above action level . Next Sample July-2027
<b>Asbestos</b>				Sample taken 09/10/24	None Detected, next Sample 9 years from prvious sample

**Abbreviations**                      **Notes**

ND= Not Detected

ppm = parts per million

ppb = parts per billion

pCi/L = picocuries per liter (a measure of radioactivity)

AL = Action Level - concentrations of a constituent which, if exceeded, triggers treatment or other requirements

mg/L= milligrams per liter

SRL=State reporting level

**From Your Water Utility**  
Hutchinson Irrigation District #16  
N. 618 Sargent Rd  
Spokane, WA 99212  
ph:509-926-4634      [hutchinsonid16@qwestoffice.net](mailto:hutchinsonid16@qwestoffice.net)

Contact Person: Nathaniel Kennicutt  
Superintendent

*Regular Scheduled Board Meetings are held every second Monday of the month at 7:30. p.m.*